



NATIONAL CERTIFIED TESTING LABORATORIES

3310 HILL AVENUE • EVERETT, WASHINGTON 98201 • TELEPHONE (425) 259-6799
FAX (425) 259-4936
www.nctlinc.com

AAMA/WDMA/CSA 101/I.S.2/A440-08 STRUCTURAL TEST REPORT SUMMARY

RENDERED TO:

**BREEZWAY LOUVRE WINDOWS
35 CAMBRIDGE STREET
COORPAROO, QLD, AUSTRALIA 4151**

MODEL/TYPE: IOS ALTAIR 4" INSIDE SCREEN JALOUSIE WINDOW

TITLE	SUMMARY OF RESULTS
Primary Product Designator	Class R – PG25 940 x 2407 mm (37 x 95 in) – Type J
Operating Force	18 N (4 lbf)
Air Infiltration/Exfiltration	3.44 L/s/m ² (0.68 cfm/ft ²) – Infiltration 2.23 L/s/m ² (0.44 cfm/ft ²) – Exfiltration
Water Penetration Resistance	180 pa (3.75 psf)
Design Pressure	± 1200 pa (25.0 psf)
Uniform Load Structural Test	± 1800 pa (37.5 psf)
Forced Entry Resistance	Passed ASTM F588-07 Grade 10

Test Completion Date: 05/11/2010

Reference must be made to QTI Report Number NS2010-334_{E0A0} dated 05/17/2010 for complete test sample description and data.

For Quality Testing, Inc:

Jim Clarke
Structural Performance Technician